

Jan Vreeburg



# Water quality in distribution: the latest developments





# **Q21-project: Water quality for the 21<sup>st</sup> century**

## **Ambition Dutch Water Companies Q21**

- Preserve the customer trust in drinking water by supplying water of impeccable quality at all times
- Systematically research all relevant areas

## **Goal distribution research Q21 Distribution**

- Asses the relation between water quality at the pumping station and water quality at the customers tap
- Is it possible to manipulate the water quality at the pumpingstation to avoid problems in the network.

## **Goal Microbiology Q21:**


- Understanding *Legionella* in networks
- Understanding the biofouling of membranes



# Q21-distribution: A network of projects and researchers

- **BTO forms the base, both vision and funding**
- **TU Delft adopted the ambitions of program → MSc and PhD students, national and international**
  - Delft Cluster is co-financing research, based on BTO ambition and financing → cream on top and scientific enhancement
  - NOM-project opens new opportunities for extension and enhancement


# Consequences of particles in the network



## Biological activity !



# Mass balance in a network






# **Particles in the distribution network**

- Particles in the network are the most important cause for discolouration problems
- Research up till now resulted in the three-stage approach:
- Fundamental
  1. Prevent particles from entering the network or prevent formation of particles (Influence NOM?)
- Operational
  2. Prevent particle accumulation → Clean the network
  3. Prevent particle sedimentation/settling → High velocities in the pipes


# Stage 1: Hypothesis effect particle load



# Resuspension Potential Measurement



Measure turbidity → RPM




# Pictures monitor connection



# Resuspension Potential Method




# Resuspension Potential Method





# Ranking standard RPM (315 m; 0,35 m/s; 15 minutes)



# Ranking RPM




## Turbidity Dr Lange, Hydrant measuring


Category \ points	0	1	2	3
Absolute max first 5 min	<3 ftu	3 –10 ftu	10-40 ftu	>40 ftu
Average first 5 min	<3 ftu	3 –10 ftu	10-40 ftu	>40 ftu
Absolute max last 10 min	<3 ftu	3 –10 ftu	10-40 ftu	>40 ftu
Average max last 10 min	<3 ftu	3 –10 ftu	10-40 ftu	>40 ftu
Time to clear	< 5 min.	5-15 min	15-60 min	>60 min



# Typical RPM results Pre and Post cleaning: Evaluation tool!




**Score 14**




**Score 1**

# Stage 1: Hypothesis effect particle load




# Application particle counters






# Track 3 → 4, 5 → 6 14 june – 21 june




WLB  
14 Juni - 21 Juni 2005






# Results: a bit more nuance compared to turbidity




# Distribution of particles: more information




## Smal particles 1-10 $\mu\text{m}$



## Middle particles 11-21 $\mu\text{m}$



## Large particles 20- >31 $\mu\text{m}$




- **Leiduin**
- **Haarlemmermeer**
- **A'veense weg**

# Particles in diameter ranges → volume



## Volume particles

— Leiduin  
— Haarlemmermeer  
— A'veense weg





# Volume → mass and composition: Time Integrated Large Volume Sampling, TILVS






# TILVS and particle counting Cooperation illustrated




# Analysis inorganics TILVS




## Aluminium




## Magnesium



## Iron



## Manganese





# Analysis mass TILVS


- Increase organich fraction to 15 - 55%
- Increase 'leaching elements' factor 4-10
- Increase iron factor 30-40
- Increase manganese factor 5-10
- Enhance TILVS protocol

# Measuring locations particle counting









# Particle counts Weesperkarspel, Diemen, Zeeburg






# Particle ranges Weespervarkspel, Diemen, Zeeburg





# Volume particles: Volume decreases and increases


## Volume Weesperkarspel, Diemen, Zeeburg



# Total particles en flow → resuspension?




## Deeltjes tellingen Zeeburg en flow



# Resuspension middle size particles




## Deeltjes tellingen Zeeburg en flow






# Conclusions particle counting and TILVS: three processes identified



Further development interpretation particle counts:  
Ramiro Rodriguez



# Stage 1: Hypothesis effect particle load developing a measuring method





# Test rig particle load



## ■ Test rig research

- Feasibility → MSc student Maarten Lut
- Further development → MSc Student Anke Grefte
- Practical application → MSc and PhD students



# Test pipe rig Ø100






# Gravitational settling is not the only process Turbophoresis can explain this



Iron Chloride 0.06 m/s

Iron Chloride 0.14 m/s





Kaolinite 0.06 m/s

Kaolinite 0.14 m/s



# Bed load transport and influence ‘bend turbulence’




# 'Old' and 'new' water





# The test pipes





# The test pipes uncovered after three (!) months




# And after six months




# Conclusions

- The concept might work: (biofilm monitor laid down)
- The smaller pipes concept is hydraulically representative
- Work out the concept in a flow through system with small pipes and test it







# Full scale test in Franeker: What happens if particel free water is supplied to a network



# The experiment with particle free water




# Detail connection research area





# Location








# The Reserach area




- 550 connections à 2,6 persons using 122 lppd (2004)
- 1970 AC part; PVC part 1974

# The Reference Area



Materiaal	Diameter (mm)	Lengte (m)
AC	300	3
AC	150	611
AC	100	1273
HPE	160	31
PVC	160	1174
PVC	110	2291
PVC	75	86
PVC	50	1684
		7152

200 m




- 520 connections à 2,7 persons using 118 lppd (2004)
- 1968-1969 AC part; 1<sup>st</sup> PVC part 1974;  
2<sup>nd</sup> PVC part 1995-1999

# Spannenburg



## Treated water Spannenburg 14 - 20 December 2004



# Measuring activities




	Research Area			Reference Area		
	Loc 1	Loc 2	Loc 3	Loc 1	Loc 2	Loc 3
Part count						
First period	14-3-06 / 30-3-06	21-3-06 / 30-3-06	14-3-06 / 30-3-06	30-3-06 / 10-4-06	30-3-06 / 10-4-06	30-3-06 / 10-4-06
Second period	12-10-06 / 18-10-06	12-10-06 / 20-10-06	12-10-06 / 20-10-06	30-10-06 / 10-11-06	30-10-06 / 4-11-06	30-10-06 / 10-11-06
Turbidity					Input UF installation 21-03-06 / 10-4-2006	
Hemoflow	21-11-06 / 27-11-06				2-11-06/3-11-06; 3-11-06/6-11-06; 6-11-06/10-11-06; 10-11-06/13-11-06	
Resuspension Potential Method (RPM)						
	1	2	3	4	5	6
-1 (2005)	24-6	27-6	24-6	24-6	24-6	24-6
0 (2005)	13-7	13-7	13-7	14-7	14-7	14-7
1 (2006)	14-3	14-3	-	14-3	-	-
2 (2006)	6-11	6-11	6-11	6-11	7-11	7-11
Cleaning period						
Initial	5 October 2005			24 June 2005		
End	9 and 10 November 2006			13 and 14 November 2006		

# Input particle volume




## Total volume particles





# Particle count/volume data


Calculated particle volume



Frequency  
percentile  
[%]

[%]	[ppb]
90,0	14,57
95,0	21,80
98,0	40,18
99,0	58,39
99,5	84,15
99,9	160,58
ratio 90/99,5	0,17
average [ppb]	9,85
surf -90 [%]	66,4%
surf +90 [%]	33,6%

Frequency distribution calculated particle volume



# Research area first period




22-3-2006 to 26-3-2006


Frequency percentile [%]	Res Loc 1 Res Loc 2	
	[ppb]	[ppb]
90,0	1,37	1,18
95,0	1,55	1,35
98,0	1,78	1,57
99,0	1,95	1,73
99,5	2,12	1,99
99,9	2,55	2,92

ratio 90/99,5	0,65	0,59
average [ppb]	0,92	0,83
surf -90 [%]	82,3%	82,5%
surf +90 [%]	17,7%	17,4%

Volume particles Research Area




Freq. Distr. Research Area 22-3-06 / 26-3-06





# Research Area second period

Volume particles Research Area



Frequency  
percentile  
[%]

	Res Loc 1 [ppb]	Res Loc 2 [ppb]	Res Loc 3 [ppb]
90,0	0,85	0,62	4,15
95,0	0,98	0,75	4,86
98,0	1,18	0,92	5,76
99,0	1,33	1,05	6,78
99,5	1,51	1,21	8,90
99,9	2,17	1,62	16,39


ratio 90/99,5

average [ppb]

surf -90 [%]

surf +90 [%]


Freq. Distr. Research Area 13-10-06 / 20-10-06






# Reference Area first period

Volume particles Reference Area




Frequency percentile [%]	Ref Loc 1 [ppb]	Ref Loc 2 [ppb]	Ref Loc 3 [ppb]
90,0	14,57	2,95	7,55
95,0	21,80	5,00	18,32
98,0	40,18	9,56	39,45
99,0	58,39	12,94	48,60
99,5	84,15	14,42	59,09
99,9	160,58	49,01	69,25
ratio 90/99,5	0,17	0,20	0,13
average [ppb]	9,85	1,98	4,49
surf -90 [%]	66,4%	56,6%	43,8%
surf +90 [%]	33,6%	43,4%	54,9%

Freq. distr. Reference area 1-4-06 / 10-4-06






# Reference Area second period




Frequency percentile [%]	31-10-2006 to 4-11-2006	
	Ref Loc 1 [ppb]	Ref Loc 2 [ppb]
90,0	9,25	6,53
95,0	18,77	11,25
98,0	36,26	20,94
99,0	49,77	30,71
99,5	117,97	39,57
99,9	307,70	55,12
ratio 90/99,5	0,08	0,16
average [ppb]	5,77	3,11
surf -90 [%]	38,2%	49,2%
surf +90 [%]	61,8%	50,4%



# What are the particles made of




## Particle distribution Research Area




# Reference Area



Particle size distribution Reference Area 98%




Particle size distribution Reference Area 25%






# Particle size distribution and volume distribution

Comparison particle size distribution




Particle volume per size range




volume particles [ppb]

Ref Loc 1 98%	40,41
Ref Loc 1 25%	5,23
Res Loc 1 98%	1,30


# Resuspension Potential Measurement



Cause a sudden increase in velocity



# Adjusted RPM: shorter disturbance



# Resuspension Potential Measurements



	Points	0	1	2	3	4
Max during disturbance [FTU]	<1	1 -3	3 – 5	5 – 10	>10	
Average during disturbance [FTU]	<1	1 -3	3 – 5	5 – 10	>10	
Resettling time [min]	<1	1-5	5-10	10-15	>15	



Research area Date location	-1 measure			0-measure			1-measure			2-measure		
	24-6-2005	13-7-2005	tot	13-7-2005	tot	14-3-2006	tot	14-3-2006	tot	6-11-2006	tot	
Res loc 1	4	4	3	11	1	1	1	3	2	1	0	3
Res loc 2	4	4	4	12	1	1	1	3	4	3	0	7
Res loc 3	4	4	3	11	1	0	1	2			0	2
Res loc 4	4	4	2	10	0	0	0	0	1	1	0	2
Res loc 5	4	4	3	11	2	1	2	5			0	1
Res loc 6	4	4	2	10	3	1	1	5			0	4
Average			10,83			3,00			4,00		4,00	

Reference area Date location	-1 measure			0-measure			1-measure			2-measure		
	22-6-2005	7-7-2005	tot	7-7-2005	tot	14-3-2006	tot	14-3-2006	tot	6-11-2006	tot	
Ref loc 1	3	2	2	7	1	1	1	3	0	0	0	0
Ref loc 2	4	4	3	11	2	1	1	4	4	4	3	11
Ref loc 3	4	4	4	12	2	1	1	4			0	4
Ref loc 4	3	3	1	7	4	3	1	8	3	1	0	4
Ref loc 5	4	3	3	10	0	0	0	0			0	4
Ref loc 6	4	3	1	8	0	0	0	0			0	4
Average			9,17			3,17			4,67		8,83	

# RPM graphical



## Average Resuspension Potential Measurement







# Cleaning both the areas

- Dedicated flushing program (1,5 m/s, uni-directional flow, clear water front)
- Continuous monitoring turbidity of flushed water
- Samples in first turn over flushed water
- Analysis samples for calibration curve TSS-FTU


# Flush plans Research Area and Reference Area




# Relation TSS-Turb



Turbidity - TSS Reference area




Turbidity - TSS research area




# Sample analyses




**Composition flush samples Research Area**




**Relative comp. flush samples Research Area**



**Composition flush samples Reference Area**



**Relative comp. flush samples Reference Area**





# Removed TSS during flushing

	Total length flushed [m]	Removed TSS [gr]	Removed TSS per meter [mg/m]
Research	5840	525,08	89,9
Reference	5370	5752,52	1071,2

# Hemoflow results



Sample	Filtered	Sample	Damp	TSS		VSS		TSS	VSS	% TSS
	volume	volume	rest	corr	absolute	Absolute	[mg]	[µg/l]	[µg/l]	
2/11/2006 - 3/11/2006	1926	0,91	359,45	243,99	115,46	43,17	59,95	22,42	37,39	
3/11/2006 - 6/11/2006	3613	0,695	302,33	208,76	93,56	20,61	25,90	5,71	22,03	
6/11/2006 - 10/11/2006	1942	0,96	364,80	274,87	89,93	19,34	46,31	9,96	21,50	
10/11/2006 - 13/11/2006	6897	0,645	364,43	194,06	170,36	44,49	24,70	6,45	26,11	
Total		14378			469,31	127,61	32,64	8,88		

**Total loaded : 2743 gr  
Total removed: 5753 gr**






# Conclusions

- Sediment primarily originates from treatment
- Particle load in Reference Area reloads the system in one-and-a-half year to starting level
- Large part of the sediment is of organic nature
- Formation of sediment in the network?
- Particle free water increases cleaning frequency with factor 5-10
- Avoiding peaks will decrease the particle load significantly



# Stage 2 and 3 are mainly aimed at operation of the network



# Stage 2: Prevent accumulation → cleaning



## ■ Crude rules → Water Flushing

- 1,5 m/s
- Clear water front
- 2 à 3 turnover pipe volume


## ■ The operational eye opener: It is almost always possible

## ■ Room for further improvement




# Test case Venlo: RPM locations

blue: PVC/Ac; red: CI



# Measuring equipment




Points	0	1	2	3	4
Max 5 minutes [FTU]	<2	2-10	10-25	25-50	>50
Average 5 minutes [FTU]	<2	2-10	10-25	25-50	>50
Resettling time [min]	<5	5-15	15-25	25-30	>30


# Results AC pipe



Turbidity data RPM 100 mm AC




RPM data 100 mm AC




# RPM results CI pipe



Turbidity data 4" CI




RPM data 4" CI




# Average RPM's



Average RPM





Average RPM





# Stage 3: Prevent settling

## ■ New design rules for distribution networks


- Looped main structure
- Branched and streamlined distribution pipes
- 20% cheaper



# Self cleaning networks: the principle



# **Self cleaning networks: case study comparing to conventional network**













# Self cleaning network




# Area 1: conventional



# Area 3: self cleaning





# Ratio in going / out going






# Comparison conventional $\leftrightarrow$ Self cleaning Ratio In/Uit in different locations



# It takes time to implement an innovation





# Recapitulation

- Operational measures to control discolouration available → further development and (international) implementation
- Fundamental knowledge about particle load, NOM and particle behavior in the network still lacking
- Measuring methods as RPM, Particle counting and TILVS must be further developed
- Test rig for quantifying effect treatment on distribution is promising
  
- Challenges enough!

Jan Vreeburg



# Water quality in distribution: the latest developments

